

WEEKLY TANK INSPECTION REPORT

WA 2917

9/17/1987

The following tanks were inspected for corrosion, leaking valves, seams or manholes.

TANK # OK NEEDS REPAIR

90 ☒ PNVCO
 91 ☒ PNVCO
 92 ☒ PNVCO
 93 ☒ PNVCO CP
 94 ☒ PNVCO
 95 ☒
 96 ☒
 97 ☒
 98 ☒
 99 ☒
 100 ☒
 101 ☒ PNVCO
 102 ☒ PNVCO
 103 ☒ PNVCO
 104 ☒ PNVCO

TANK # OK NEEDS REPAIR

105 ☒
 106 ☒
 107 ☒
 108 ☒
 109 ☒
 110 ☒
 111 ☒
 112 ☒
 113 ☒ PNVCO
 114 ☒
 115 ☒
 116 ☒
 117 ☒
 118 ☒
 165 ☒

FILE COPY

All tank yard berms OK ☒ NEEDS REPAIR

SEAL YARD berms OK ☒ NEEDS REPAIR

yard berms OK ☒ NEEDS REPAIR

ADDITIONAL COMMENTS approx 6000 gallons of water in the small yard, takes as if the meter discharging tank # 112 was over filled.

Reported for the week of 9-17 19 87

Signed John M. Markus

USEPA RCRA



3012730

WEEKLY TANK INSPECTION REPORT

The following tanks were inspected for corrosion, leaking valves, seams or manholes.

C. #	OK	NEEDS REPAIR	TANK #	OK	NEEDS REPAIR
90	✓		105	✓	
91			106	✓	
92		↓ PND	107	✓	leaky bolts
93			108	✓	
94	✓		109	✓	
95		PND	110	✓	Broken boom cable
96	✓		111	✓	
97	✓		112	✓	
98	✓		113		PND
99	✓		114	✓	
100	✓		115	✓	
101		↑ PND	116	✓	
102			117	✓	
103			118	✓	
104			165	✓	

11 tank yard berms OK ☒ NEEDS REPAIR

SEL YARD berms OK ☒ NEEDS REPAIR

yard berms OK ☒ NEEDS REPAIR

ADDITIONAL COMMENTS

Reported for the week of 9-18-87 1987

Signed Walter Matthews